

COUNCIL ACTION FORM

SUBJECT: WATER POLLUTION CONTROL FACILITY ELECTRICAL SWITCHGEAR REHABILITATION PROJECT

BACKGROUND:

On July 26, 2011, the City Council awarded a contract to Ziegler Power Systems of Altoona, Iowa in the amount of \$31,854.00 to provide all labor, equipment, materials, and other components necessary to complete the Water Pollution Control (WPC) Facility Electrical Switchgear Rehabilitation Project.

During the project, damages to City equipment in the amount of \$3,434.00 occurred due to improper temporary power supplied by Ziegler Power Systems. That equipment has been repaired, and Ziegler Power Systems has issued a credit for the amount of the repairs.

As of March 23, 2012, work for the WPC Facility Electrical Switchgear Rehabilitation Project was completed in accordance with the contract and the City's specifications, and an Engineer's Statement of Completion has been received.

ALTERNATIVES:

1. Accept completion of the WPC Facility Electrical Switchgear Rehabilitation Project and authorize final payment in accordance with the contract awarded to Ziegler Power Systems of Altoona, Iowa in the amount of \$28,420.00.
2. Do not accept completion of the WPC Facility Electrical Switchgear Rehabilitation Project.

MANAGER'S RECOMMENDED ACTION:

An Engineer's Statement of Completion has been prepared by Paul Kaeding of Barr Engineering Company certifying that all work on the rehabilitation of the Electrical Switchgear has been satisfactorily completed.

Therefore, it is the recommendation of the City Manager that the City Council adopt Alternative No. 1, thereby accepting completion of the WPC Facility Electrical Switchgear Rehabilitation Project contract with Ziegler Power Systems of Altoona, Iowa and authorizing final payment in the amount of \$28,420.00.