ITEM # 32 DATE: 9-22-15

COUNCIL ACTION FORM

<u>SUBJECT</u>: RIVER VALLEY PARK IRRIGATION PROJECT

BACKGROUND:

T&T Sprinkler Services Inc, was awarded the contract to provide all labor, equipment, and other components necessary to complete the River Valley Park Complex Irrigation Project. Council awarded the contract on February 10, 2015 in the amount of \$107,125 for the base bid and alternates #1 and #2.

ALTERNATIVES:

- 1) Accept completion of the River Valley Complex Irrigation Project Improvements in the amount of \$107,125.
- 2) Do not accept the completion of the River Valley Complex Irrigation Project Improvements in the amount of \$107,125.

MANAGER'S RECOMMENDED ACTION:

T&T Sprinkler Services Inc, has completed the work required as specified in the bid specifications. The letter of completion from the design firm EC Design, West Des Moines, Iowa is attached.

Therefore, it is the recommendation of the City Manager that the City Council adopt Alternative No. 1, accepting completion of the River Valley Complex Irrigation Project Improvements in the amount of \$107,125.

Main Office

 $$400\mbox{ - }5^{th}$$ Street West Des Moines, IA 50265

Phone: (515) 225-6365 Fax: (515) 225-6366

Irrigation Memorandum

To: Kyle Jacobsen Date: 8/28/15

From: Lisa Rudish

RE: River Valley Park Irrigation Walk-Thru Site Visits 7/31/15 & 8/27/15

Attendees:

Lisa Rudish – EC Design Group, Ltd. Kyle Jacobsen & Pat Wynja – Ames Park & Recreation Mike & Nathan Meston – T & T Sprinkler

Field Observations:


 Reviewed overall installation on north and south fields as well as the status of the irrigation system. The system is complete and operating well. Following are our observations and comments:

- Irrigation zones and all components are installed as per specifications and complete.
- T & T is working with Toro to provide compatible remote/handheld radio solution for the fields as some parts have been discontinued.
- T & T has provided Kyle and staff with training of the products and user manuals as required and per spec.
- As-built drawings with zone numbers will be provided.



Photos illustrate zones operating with good head-to-head coverage, installation of electric and manual valves in valve boxes and controller mounts.









Please notify the office of EC Design Group, Ltd. in writing if you feel the information above is not factual or misrepresented within 10 days or the said memo shall stand as written.