

COUNCIL ACTION FORM

SUBJECT: WPCF RAW WATER PUMP STATION ELBOW REPLACEMENT

BACKGROUND:

The Water Pollution Control Facility (WPCF) was constructed in 1989. The piping in the facility is original to the 1989 construction. On September 4, 2014 a 30" elbow sprung a leak due to age and wear on the pipe. An emergency repair was made, but staff became concerned about the integrity of two other elbows in the process piping.

On May 26, 2015, Council awarded a contract to Eriksen Construction Company in the amount of \$35,000 for the replacement of two elbows associated with the process piping in the Raw Water Pump Station at the WPCF.

All work under this contract was completed in accordance with the plans and specifications on February 5, 2016. One change order regarding an extension to the completion date was issued for this project. The remaining contract amount due to the contractor is \$1,750.

ALTERNATIVES:

1. Accept completion and authorize final payment, in accordance with the contract, to Eriksen Construction Company of Blair, Nebraska.
2. Do not accept completion of the project at this time.

MANAGER'S RECOMMENDED ACTION:

Work for the Water Pollution Control Facility Raw Water Pump Station Project has been completed in accordance with the plans and specification, and the engineer has provided a Certificate of Completion. It is the recommendation of the City Manager that the City Council adopt Alternative No. 1, thereby accepting the completion on this contract with Eriksen Construction Company and issuing final payment.