ITEM # <u>32</u> DATE: 04-14-20

COUNCIL ACTION FORM

SUBJECT: CONTRACT RENEWAL – ELECTRIC SERVICES TRANSFORMERS

BACKGROUND:

This contract is for the purchase of transformers necessary to meet the anticipated needs of the Electric Services Department. These transformers are kept on hand to enable staff to replace failed transformers quickly.

Typically, these transformers are used to provide service for commercial and residential applications. It is also necessary to meet the anticipated needs of the Electric Services Department for new service and maintenance activities. Transformers would be purchased by the City as requested on a quarterly basis. This contract provides the City with inventory management flexibility and also helps to reduce the need for extensive storage space.

On February 23, 2016, City Council awarded a contract to RESCO, Ankeny, IA, for the purchase of these transformers in accordance with unit prices bid. This contract included the option for the City to renew in one-year increments for up to four additional years. Staff recommends renewing the agreement for the period of April 1, 2020 through March 31, 2021. Council should note that there are no price increases for the 2020-2021 contract period. This is the fourth renewal out of four possible renewal periods.

The transformers are purchased from an Electric Department inventory asset account and charged to the appropriate operations accounts as the transformers are put into use. Council should note that no contract amount is being authorized at this time, since payments will be based on unit prices and quantities ordered.

ALTERNATIVES:

- 1. Approve the contract renewal with RESCO, Ankeny, Iowa, for the purchase of Electric Services transformers in accordance with unit prices.
 - Transformers will be purchased quarterly. Payments will be based on unit prices and actual quantities ordered, plus applicable sales taxes.
- 2. Reject the renewal and attempt to purchase electric transformers periodically at market prices at the time of purchase.

CITY MANAGER'S RECOMMENDED ACTION:

It is important to purchase transformers at the lowest possible cost with minimal risk to the City. It is also imperative to have these transformers available to meet customer needs.

Therefore, it is the recommendation of the City Manager that the City Council adopt Alternative No. 1 as stated above.

			Sell Price	Sell Price	Sell Price	Sell Price					
Туре		Sell Price	Renewal	Renewal	Renewal	Renewal					
KVA	Est Qty	4/31/16 thru	4/1/17 to	4/1/18	4/1/19	4/1/20	NL	LL			
NVA		3/31/17	3/31/18	to 3/31/19	to 3/31/20	to 3/31/21					
Group	l Padmoi	unt Transformer		(0 3/31/13	10 3/31/20	(0 5/ 51/ 21					
Division 1 Single Phase Padmount 120/240 Volts											
25	5	\$1,259.94	\$1,293.88	\$1,325.70	\$1,391.98	\$1,391.98	66	207			
37.5	10	\$1,477.06	\$1,516.33	\$1,553.62	\$1,631.30	\$1,631.30	80	315			
50	10	\$1,513.76	\$1,554.09	\$1,592.31	\$1,671.92	\$1,671.92	102	442			
75	2	\$1,901.02	\$1,948.98	\$1,996.91	\$2,096.75	\$2,096.75	143	582			
100	2	\$2,463.27	\$2,525.52	\$2,587.62	\$2,717.00	\$2,717.00	180	643			
Divisio	n 2 Three		nt Transformer		. ,	. ,					
112.5	0	\$5,535.17	\$5,680.62	\$5,820.31	\$6,111.32	\$6,111.32	231	1009			
150	3	\$5,674.82	\$5,824.49	\$5,967.72	\$6,266.10	\$6,266.10	318	1339			
225	0	\$6,682.98	\$6,859.19	\$7,027.86	\$7,379.25	\$7,379.25	379	1864			
300	3	\$8,179.41	\$8,394.90	\$8,601.33	\$9,031.40	\$9,031.40	474	2116			
500	3	\$10,041.79	\$10,306.13	\$10,559.56	\$11,087.54	\$11,087.54	634	3891			
750	1	\$14,586.14	\$14,969.39	\$15,337.49	\$16,104.36	\$16,104.36	843	5211			
1000	1	\$15,535.71	\$15,927.56	\$16,319.22	\$17,135.18	\$17,135.18	1056	7918			
Divisio	n 3 Three	e Phase Padmou	nt Transformer	480Y/277 Volts,	Loop Feed Swit	tches					
300	2	\$7,469.93	\$7,666.33	\$7,854.85	\$8,247.59	\$8,247.59	487	2387			
500	2	\$10,141.69	\$10,408.17	\$10,664.11	\$11,197.31	\$11,197.31	645	4311			
750	2	\$12,027.52	\$12,343.88	\$12,647.42	\$13,279.79	\$13,279.79	915	4993			
1000	1	\$15,322.12	\$15,724.49	\$16,111.16	\$16,916.72	\$16,916.72	1104	5915			
1500	1	\$19,182.33	\$19,635.90	\$20,118.75	\$21,124.69	\$21,124.69	1630	8225			
Divisio	n 4 Three	e Phase Padmou	nt Transformer	277/480 Volts, S	Standard 55*C F	Rise					
2500	1	\$28,611.20	\$29,287.18	\$30,007.36	\$31,507.73	\$31,507.73	2485	####			
Group	II Overhe	ead Transformer	'S								
Divisio	n 1 Single	e Phase Polemo	unt 120/240 Vol	ts							
5	0	\$517.42	\$531.29	\$544.35	\$571.57	\$571.57	21	58			
10	0	\$592.21	\$608.21	\$623.17	\$654.32	\$654.32	30	106			
15	2	\$635.25	\$652.31	\$668.35	\$701.77	\$701.77	39	160			
25	6	\$818.65	\$841.03	\$861.71	\$904.80	\$904.80	62	209			
37.5	1	\$967.21	\$992.83	\$1,017.24	\$1,068.11	\$1,068.11	78	330			
50	5	\$1,024.59	\$1,052.31	\$1,078.19	\$1,132.10	\$1,132.10	110	442			
75	2	\$1,557.38	\$1,598.98	\$1,638.30	\$1,720.21	\$1,720.21	153	576			
100	1	\$2,222.34	\$2,281.03	\$2,337.12	\$2,453.98	\$2,453.98	168	651			
Division 2 Single Phase Polemount Transformer 277/480 Volts											
15	1	\$628.07	\$645.13	\$660.99	\$694.04	\$694.04	42	153			
25	1	\$812.50	\$833.85	\$854.35	\$897.07	\$897.07	60	220			
37.5	1	\$1,017.42	\$1,045.13	\$1,070.83	\$1,124.37	\$1,124.37	84	284			
50	1	\$1,020.49	\$1,048.21	\$1,073.99	\$1,127.68	\$1,127.68	104	420			

75	1	\$1,620.90	\$1,663.59	\$1,704.50	\$1,789.72	\$1,789.72	134	559
100	1	\$2,091.19	\$2,146.66	\$2,199.45	\$2,309.42	\$2,309.42	170	639