



**Public Works Department**  
515 Clark Avenue, Ames, Iowa 50010  
Phone 515-239-5160  
Fax 515-239-5404

February 26, 2010

Honorable Mayor and Council Members  
City of Ames  
Ames, Iowa 50010

Ladies and Gentlemen:

I hereby certify that the utilities and asphalt base paving required as a condition for approval of the final plat of **Walnut Ridge, 2<sup>nd</sup> Addition** have been completed in an acceptable manner by Ames Trenching and Manatt's. The above mentioned improvements have been inspected by the Engineering Division of the Public Works Department of the City of Ames, Iowa and found to meet city specifications and standards.

As a result of this certification, it is recommended that the financial security for public improvements on file with the City for this subdivision be released in full.

Sincerely,

John Joiner, P.E.  
Public Works Director  
City of Ames

JJ/ec

cc: Finance, Contractor, PW Admin Asst, Construction Supervisor, PW Senior Clerk,  
Planning & Housing

Description	Unit	Quantity
Excavation and Embankment	CY	2,300
Clearing and Grubbing	LS	1
Silt Fence	LF	700
Inlet Protection	EA	6
Stabilized Construction Entrance	EA	1
Straw Mulch	ACRE	1
Seeding, Type (5) Stabilizing Crop	ACRE	1
4-inch Sanitary Sewer Service	EA	11
8-inch Water Main	LF	350
8-inch 45 Degree M.J. Bend	EA	2
8"x6" M.J. Reducer	EA	2
8-inch M.J. Gate Valve	EA	2
Hydrant and Hydrant Run (includes 8"x6" Reducer, 6" M.J. Gate Valve, 6" Pipe and Hydrant)	EA	1
1" Water Service	EA	11
15-inch RCP, Class III	LF	246
18-inch RCP, Class III	LF	54
18-inch RCP Apron	EA	1
4-inch Perforated Tile	LF	110
Tile Cleanout	EA	2
Rip Rap	TON	5
1.5-inch Sump Service	EA	11
Manhole/Intake Adjustment (Minor)	EA	4
Subgrade Preparation	SY	1,875
30-inch P.C.C. Curb and Gutter	LF	848
6-inch P.C.C. Pedestrian Ramp	SY	12
Detectable Warning Material	SF	20
8-inch H.M.A. Pavement	SY	1,450
Manhole Boxout	EA	2
Temporary Traffic Control	LS	1